

ADDENDUM #1  
Electric Car Charging Stations  
CONTRACT #2023-11  
REGIONAL WATER RESOURCE  
AGENCY

DATE: July 28, 2022

The attention of persons and businesses bidding on this project is called to the following change in the drawings and/or specifications and/or bid documents:

*The written statements of clarification, interpretation or corrections hereby modify the bidding documents by addition, deletions, or corrections and shall become a legal and binding part of the Contract Documents for this project. Bidders shall acknowledge receipt of the addendum by inserting its number and date in the Proposal Form. Failure to do so may subject the bidder to disqualifications.*

1. Can the bid response be emailed or does it have to be mailed/couriered/hand delivered? **They need to be mailed/couriered/hand delivery at this time.**
2. Can you confirm the total number of stations to be included in the bid are (3) Level 2 station and (1) DCFC station? – **This is correct**
3. Are the Level 2 stations single port or dual port? – **Single Port**
4. Shipping Charges: Usually FOB delivery terms do not include unloading by carrier. Customers have to be able to receive items themselves. Particularly DCFC stations might require availability of forklift or other mechanical equipment to unload EVSE. Please clarify this is okay? – **RWRA will provide forklift to offload off of carrier's truck. RWRA will offload from the REAR/Gate of the carrier's truck.**
5. Level 2 EVSE: Standard Output power is 14.4kW per dual port station or 7.2kW per port. Is that acceptable? – **RWRA is requesting 19,2kW single port charging station.**
6. Is 23' feet of cable length acceptable? Standard is 18' - **Specifications call for Minimum 25'. If less is provided, please note the exception on the bid form in the Exceptions Tab. All exceptions will be taken into account when evaluating bids for an advantageous award.**

7. DCFC station: Can the unit be stand-alone 120kW with simultaneous charging capacity of 60kW per port or 120kW for single port. Even modular units will need a second Power Station/Rectifier/Cabinet to add more than (2) dispensers. Unless you request to quote for a 350kW power cabinet that can support up to (4) dispensers. – Yes, 2 ports on the unit, 1 @ 120kW or 2 simultaneously at 60kW. Specifications state the requirement: “Connector Configurations: 2x 60kW simultaneously, 1x 120kW sequentially”
8. Is a 20' cable length acceptable on DCFC 120kW station? - Specifications call for Minimum 25'. If less is provided, please note the exception on the bid form in the Exceptions Tab. All exceptions will be taken into account when evaluating bids for an advantageous award.
9. What is the subscription term to be include for both Level 2 and DCFC stations (1 year, 5 years etc.) – Submit standard terms and conditions for supplier. Minimum term would be annual renewal (12 mo).
10. Is the Quotation sheet available in excel format to provide RWRA additional line items and options? Is available in Word, not excel
11. Can we reserve signing the Indemnity agreement until after award is declared, to discuss provisions with RWRA prior to contract completion? No