

**ADDENDUM #1
CIPP F/Y 23-1
CONTRACT #2023-13
REGIONAL WATER RESOURCE AGENCY**

DATE: September 9, 2022

The attention of persons and businesses bidding on this project is called to the following change in the drawings and/or specifications and/or bid documents:

The written statements of clarification, interpretation or corrections hereby modify the bidding documents by addition, deletions, or corrections and shall become a legal and binding part of the Contract Documents for this project. Bidders shall acknowledge receipt of the addendum by inserting its number and date in the Proposal Form. Failure to do so may subject the bidder to disqualifications.

1. What type of rehabilitation will be used on the pipes? If it's Cured-In-Place Pipe (CIPP) lining, will it be heat-cured or light-cured?

CIPP, heat cured, the Contractor may propose UV light cure in their bid, but acceptance is not guaranteed.

2. Will the pipes be cleaned and/or televised before and after rehabilitation?

It is the Contractors responsibility to provide pre and post lining video and inspection logs.

3. What are the lengths and sizes of the pipes to be cleaned and/or televised?

See bid form, approximately 10,800 linear feet total of 8" to 24" pipes.

4. How much is the estimated cost of the project?

NA

5. Will RWRA provide video inspection of each line item to review prior to bid?

Yes, see link below

<https://youtube.com/playlist?list=PLAYWHtN8ZL8key9SbGfQvJbSig0zoLVhK>