

ADDENDUM #2
CIPP F/Y 23-1
CONTRACT #2023-13
REGIONAL WATER RESOURCE AGENCY

DATE: September 19, 2022

The attention of persons and businesses bidding on this project is called to the following change in the drawings and/or specifications and/or bid documents:

The written statements of clarification, interpretation or corrections hereby modify the bidding documents by addition, deletions, or corrections and shall become a legal and binding part of the Contract Documents for this project. Bidders shall acknowledge receipt of the addendum by inserting its number and date in the Proposal Form. Failure to do so may subject the bidder to disqualifications.

1. Will Railroad permits be required for any portion of this work?

There are no pipe segments in this project that enter rail-way right of way that RWRA is aware of.

2. Article 4.02 seems to indicate both 120 days substantial completion and 120 days final completion. Should this be 120 days substantial completion and 150 days final completion?

Both contract times are set to be 120 days, as called out in the specifications.

3. Is Hydrotite by Greenstreak an approved equal for the Insignia end seals?

As of this time, Hydrotite by Greenstreak is NOT an approved end seal.