

ADDENDUM #1
David Hawes Plant
Non Potable Water Line
CONTRACT #2023-17
REGIONAL WATER RESOURCE AGENCY

DATE: November 7, 2022

The attention of persons and businesses bidding on this project is called to the following change in the drawings and/or specifications and/or bid documents:

The written statements of clarification, interpretation or corrections hereby modify the bidding documents by addition, deletions, or corrections and shall become a legal and binding part of the Contract Documents for this project. Bidders shall acknowledge receipt of the addendum by inserting its number and date in the Proposal Form. Failure to do so may subject the bidder to disqualifications.

1. **The bid opening for this project will be extended to November 17th, at 2:00 PM at the same location as described in the bid documents.**

The last day to ask questions and receive written answers or clarifications will be close of business on November 11th.

2. **Would RWRA consider allowing the Notice to Proceed date to be pushed to February or March?**

RWRA will allow the Notice to Proceed date to be issued no later than January 1st.

3. **In regards to the East Tie In location, would RWRA consider allowing the contractor to install the pipe by open cut method, routed around the South side of the building and underneath the over head door, rather than going under the press building wall as proposed in the bid plans?**

RWRA is agreeable to this installation method, see attached for clarification of this location (revised appendix A from specifications). The contractor shall be allowed to locate the stand pipe at either holding tank, and discharge into the top of either tank, exact location and supports shall be subject to approval.

- 4. Is this line subject to super chlorination requirements for disinfection like potable water lines?**

No, this line is for non-potable water, as installed and not disinfected is acceptable.

