

**ADDENDUM #2
Horsefork Pump
Station Building Re-Roof
CONTRACT #2023-25
REGIONAL WATER RESOURCE AGENCY**

DATE: February 23, 2023

The attention of persons and businesses bidding on this project is called to the following change in the drawings and/or specifications and/or bid documents:

The written statements of clarification, interpretation or corrections hereby modify the bidding documents by addition, deletions, or corrections and shall become a legal and binding part of the Contract Documents for this project. Bidders shall acknowledge receipt of the addendum by inserting its number and date in the Proposal Form. Failure to do so may subject the bidder to disqualifications.

1. The spec on the Horse Fork pump station calls for walk pads. Do you want a path to the units or do you just want them installed at the serviceable side of the units?

•Walk pads are specified on the Horsefork Roof to safely service the RTU on the roof top. Walk pads/path shall be provided across the roof from access point to service all sides of the HVAC RTU.