

ADDENDUM #1
COMBINED SEWER SYSTEM HYDRAULIC MODELING
CONTRACT #2025-25
REGIONAL WATER RESOURCE AGENCY

DATE: February 6, 2025

The attention of persons and businesses bidding on this project is called to the following change in the drawings and/or specifications and/or bid documents:

The written statements of clarification, interpretation or corrections hereby modify the bidding documents by addition, deletions, or corrections and shall become a legal and binding part of the Contract Documents for this project. Bidders shall acknowledge receipt of the addendum by inserting its number and date in the Proposal Form. Failure to do so may subject the bidder to disqualifications.

1. Is there a pre-proposal meeting scheduled?
There is no pre-proposal meeting scheduled
2. Does this proposal have a page limit?
There is no page limit to the overall proposal. However, resumes shall be limited to one page per staff member and Statement of Project Understanding shall be two pages maximum.
3. The RFQ mentions 1,500 nodes and links. Is there a desired minimum diameter pipe size that these 1,500 nodes and links would include?
1,500 nodes and links accounts for most 12" diameter pipes and larger, as well as some smaller diameter pipes connecting isolated subbasins.